

Issued	31-08-2018	Scope	---
Report	2002888	Page	1 of 2
PIN	0476CT2888		

Kiwa Cermet Italia hereby attests that the central heating boilers:

Trade mark:

SYLBER

Logo



Models:

*as specified in the **Annex 1***

are covered by the the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Appliance type: B_{11BS}

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI,
FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK,
MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups: *as specified in the **Annex 1***

The assessment tests have been performed using the following standard as
guidelines:
EN 15502-1:2012+A1:2015, EN 15502-2-2:2014

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it


www.kiwa.it

www.kiwacermet.it

GASTEC

The present declaration doesn't substitute the EC certificate nr. KIP-15919/G
This declaration is valid until withdrawal or replacement of the above mentioned EC
certificate

Industry Division Manager
Maurizio Lorenzon



Issued 31-08-2018 Scope ---
Report 2002888 Page 2 of 2
PIN 0476CT2888

ANNEX 1

Models

Style 24 A Bx

are approved for following gas groups

Group	mbar
E	20
Lw	20

Group	mbar
H	20;25
Ls	13

Group	mbar
P	37;50

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755


Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

G A S T E C



Number KIP-15919/E Replaces ---
Issued 31-08-2018 Scope Directive 92/42/EEC
Regulation (EU) No. 813/2013
Report 2002888 Page 2 of 2
PIN 0476CT2888

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Model:

	Style 24 A Bx
η_{100}	90,1 %
η_{30}	89,2 %
η_4	81,1 %
η_1	80,3 %
P_4	24,1 kW
P_1	7,1 kW
C.Heater?	Yes
B ₁ Boiler?	Yes
Type of boiler:	Other

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)

η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)

η_4 = At rated heat output and high-temperature regime - GCV (*)

η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)

P_4 = At rated heat output and high-temperature regime (*)

P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensig Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with gas G20.

(n.t. = not tested)

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

CERTIFICATE

Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia

Holding Srl

Via Cadrano, 23

40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34

31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC