



DECLARATION

Issued	26-06-2019	Scope	---
Report	2003754	Page	1 of 1
PIN	0476CU3754		

Herewith Kiwa Cermet Italia S.p.a. declares that the central heating condensing boilers

Test report no. 2003754

Trade mark: SYLBER

Models: LINEA 25C p,
LINEA 30C p,
LINEA 35R p,
LINEA 35C p

are fitted for outdoor use in partially protected place according to
EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016
with minimum ambient tempertaure of -15°C.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

Industry Division Manager
Maurizio Lorenzon

GASTEC