

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085AQ0713Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EC Efficiency Directive (92/42/EEC)
EG-Wirkungsgradrichtlinie (92/42/EWG)**Distributor**
*Vertreiber*SYLBER
Via Risorgimento, 13, D-23900 Lecco**Product Category**
Produktart

Boilers with flue systems: Condensing water heater (3202)

Product Description
Produktbezeichnung

Condensing boiler (cascade) with fan-assisted burner, electrical ignition and ionisation flame supervising

Model
Modell

SYLBER Queen ...; PRINCE ...

Type of Boiler
Heizkesseltyp

condensing boiler

Test Reports
Prüfberichte

supplement test: B16/02/2114/EU from 19.02.2016 (DBI)

Test Basis
Prüfgrundlagen

EU/92/42 (21.05.1992)

File Number
Aktenzeichen

16-0138-GWR

70029-04-A-DE

21.06.2016 Rie J-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
SYLBER Queen 50	nominal heat output: 13,3...44,2 kW heat input (Hi): 13,5...45,0 kW	
SYLBER Queen 100	nominal heat output: 13,3...88,3 kW heat input (Hi): 13,5...89,9 kW	
SYLBER Queen 50 DEP; PRINCE DEP 50; PRINCE 50 DEP SR	nominal heat output: 13,3...34,2 kW heat input (Hi): 13,5...34,8 kW	
SYLBER Queen 100 DEP	nominal heat output: 13,3...68,3 kW heat input (Hi): 13,5...69,6 kW	
PRINCE 35; PRINCE 35 SR	nominal heat output: 5,2...30,9 kW heat input (Hi): 5,2...31,5 kW	
PRINCE 50; PRINCE 50 SR	nominal heat output: 13,3...44,2; 12,9...40,1 (Ls) kW heat input (Hi): 13,5...45,0; 13,1...40,8 (Ls) kW	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The above listed model was certified under the Product-Identnumber CE-0085AQ0713 according to the Gas Appliance Directive (2009/142/EC).

